

@@@@@

6"x20" GRANITE CURBING

5" AND 8" 4000 PSI CONCRETE WALK

12" PROCESSED TRAPROCK

3.5" BITUMINOUS CONCRETE - CLASS 4 BASE COURSE

1.5" BITUMINOUS CONCRETE - CLASS 1 POINT OF APPLICATION OF GRADE **EGEND**

888

6" UNDERDRAIN WHERE REQUIRED

SUITABLE SUB GRADE SHAPED AND COMPACTED

LOAM AND SEED ON 6" TOPSOIL OR 2" BIT. CONCRETE SURFACE ON 12" TRAPROCK TO BE DETERMINED BY THE ENGINEER. 6" TO 12" BANK RUN GRAVEL

DESIGN CRITERIA:

DESIGN CONTROLS:

Introduction:

2001" by American Association of State Highway and Transportation Officials", (AASHTO), current edition, or as amended within the City of Hartford. The materials, dimensions, utilities and amenities shown are subject to the approval of the City of Hartford, Department of Public Works under the applicable provisions of the City of Hartford Municipal Code.

The City reserves the right to amend or modify any part of these guidelines for any Street, as defined by "A Policy on Geometric Design of Highways and Streets, This drawing is provided for the purpose of establishing the minimum design guidelines with respect to the construction of a Local 윽

Roadway Geometry shall conform requirements of Chapter 7, Rural Arterials of the AASHTO manual. to the and Urban

Utilities:

Line assignment for utillity facilities shall be located within the curb to curb width. Such line assignments will be issued by the Department of Public Works.

The Department of Public Works has developed a City wide Traffic Calming Master Plan. street projects shall incorporate elements of this plan.

Traffic Calming:

The City Engineer should be consulted as to which traffic calming device is to be incorporated on a specific roadway.

Illumination:

light level within the ROW. Fixtures shall be "Dark Skies" compliant unless otherwise approved by the Director of Public Works. Illumination design shall conform to IESND standards with a 1.0 footcandle average

Applicable permits that may be required are, but not limited to: City of Hartford, Department of Public Works Construction Permit, Metropolitan District Developer's Permit, DEP Stormwater Discharge Permit. It is the developer's responsibility to

erify and obtain all required permits.

Design criteria based on "AASHTO—Geometric Design of Highways and Streets", 4th Edition, 2001.

Sidewalk Cross Slope:

2% Max.

Sidewalk Width: Pavement Cross Slope: Shoulder Width:

1.5%-2.0%

Tree Belt

Curb to Curb Width:

30°

Travel Lane Width:

CROSS SECTION ELEMENTS:

component range.

This manual should be referenced to obtain the accurate design values for the applicable

Handicapped accessible ramps shall be installed at every location where a pedestrian street crossing is planned. T ramp shall not exceed a slope of 1:12. design shall be compliant with current requirements. The

Construction shall conform to the following specifications: City of Hartford Technical Specifications, Metropolitan District Standards and Specifications, State of Connecticut Department of Transportation Standard Specifications for Roads, Bridges and Incidental Construction. Other specifications relative to specific utilities may be

Specifications:

Stopping Sight Distance:

ALIGNMENT ELEMENTS:

Vertical Curve (k): Maximum Grade: Minimum Grade: Minimum Radius:

> 0.5**%** 12**%** 148,

> > (e=4%)

Crest Sag

ROW Width:

Design Speed:

Level of Service:

25 mph C-D

applicable.

TYPICAL ROADWAY CROSS SECTION

Revisions

Ву

Date

Notice

Manual revisions to this drawing are proibiled. The use of this drawing by any corporation, or by any person, for any reason, without written authorized consent of The City of Hartford is prohibited.

Drawn

Sign-Offs

Ву

Date

Checked Recommended

Recorded Approved

Drawing Scale: As noted

Job No. 405121

Date:

City of Hartford - Department of Public Works Hartford, Connecticut, 06103

City of Hartford, Connecti Department of Public Works

cut

Sheet No.

TYPICAL ROADWAY SECTIONS LOCAL

August 2006

File Name: